

**BOARD OF EDUCATION
RAMAPO INDIAN HILLS REGIONAL HIGH SCHOOL DISTRICT**

131 YAWPO AVENUE
OAKLAND, NEW JERSEY 07436

RAMAPO HIGH SCHOOL
Franklin Lakes, N.J. 07417
(201) 891-1500

(201) 416-8100
FAX (201) 416-8123

INDIAN HILLS HIGH SCHOOL
Oakland, N.J. 07436
(201) 337-0100

October 25, 2021

Dear School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, the Ramapo-Indian Hills Regional School District began testing our schools' drinking water for lead.

In accordance with the Department of Education regulations, the District has implemented immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This included turning off the outlet, providing an alternate water source, and leaving the outlet off.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for our building. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 112 samples collected, a total of 9 sample locations exceeded the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

Table 1 at the end of this memorandum identifies the drinking water outlets that tested above the 15 µg/l for lead on a 1st-Draw sample, the actual lead level, and what temporary remedial action has taken to reduce the levels of lead at these locations.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. Federal regulations banned the use of lead solder containing

greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.


For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 AM and 4:00 PM and are also available on our website at www.rih.org. For more information about water quality in our schools, contact Paulinus Egu, Coordinator of Facilities and Operations at the Ramapo Indian Hills Regional High School, 201-416-8100, ext 3816.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,



Dr. Anthony Riscica
Interim Superintendent of Schools

Table 1: Water Outlets with Greater than 15 µg/L for Lead

Sample Location	Results (µg/l or ppb)	Remedial Action
<u>Ramapo High School</u>		
Kitchen Food Prep Sink: R-020-K-FP-1-6	23.5	All water outlets were promptly shut off. The fixtures at each outlet will either be repaired or replaced and then re-sampled.
Home Economics Sink: R-401-O-EC-41	16.6	
<u>Indian Hills High School</u>		
Corridor Spigot: I-087B-O-DW-11A-1	30.8	The outlets will remain out of service until acceptable laboratory results for Lead are obtained.
Corridor Bubbler: I-411G-C-DW-31-1	29.5	
Kitchen Food Prep Sink: I-58-K-FP-38-1	21.8	Alternate sources of drinking water are located nearby these water outlets.
Kitchen Outlet: I-58-K-KC-43-1	18.2	
Kitchen Food Prep Sink: I-58-K-FP-49-1	130	
Corridor Bubbler: I-312A-C-DW-56-1	18.6	
Kitchen Outlet: I-105-O-KC-58-1	27.8	